



® **ATLAS WIRE LLC.**
 1601 Glenlake Av.
 Itasca, ILLINOIS 60143
 (847) 678-1210
 (847) 678-1281
 www.atlaswirecorp.com



Atlas Wire, LLC
 Registered to ISO9001:2015
 and IATF 16949:2016
 Itasca, IL 60143
 Reference No. 10000854



Atlas Wire, LLC
 Registered to ISO9001:2015
 Tucson, AZ 85714
 Reference No. 10003647

MATERIAL SPECIFICATION SHEET

#18 16/30 BC 1/32" PVC
RoHS COMPLIANT
UL FIXTURE WIRE and AWM STYLE 1015 105c-600V
or CSA TEW 105C-600V VW-1

CONDUCTOR:	#18 16/30 BC 1"	
	APPROXIMATE NOMINAL O.D.	.048"
	APPROXIMATE CIRCULAR MILL AREA	1,600
	WEIGHT PER THOUSAND FEET	5.00#
	BASIC SPECIFICATION	ASTM B 174
PVC:	TEMPERATURE RATING	105c
	VOLTAGE RATING	600 VOLTS
	ELONGATION	330% AVG
	SPECIFIC GRAVITY	1.32
	DUROMETER (SHORE)	91 (A)
	TENSILE STRENGTH	2,450 PSI AVG
	OXYGEN INDEX	28
	BRITTLE POINT	-24c
	SPARK TESTED	10,000 VOLTS
	FINISHED O.D.	.110"
	WEIGHT PER THOUSAND FEET	9.70#
USE:	INTERNAL WIRING OF APPLIANCES; OR INTERNAL WIRING OF APPLIANCES WHERE EXPOSED TO OIL AT A TEMPERATURE NOT EXCEEDING 60c. 2,500v PEAK FOR ELECTRONIC USE ONLY	

info@atlaswirecorp.com